


---

# Overview of AdCal Model

Dr. Eoin Clifford,  
EirGrid

# AdCal Overview

- Generation Adequacy Model (like CREEP)
- Weighs up supply against demand
- Calculates for each half hour of the year
- Supply inputted as a list of generators, with capacities, FOPs, and SODs
- Demand inputted as yearly load curve




# AdCal Overview

- FOPs give probabilistic element to generation
- AdCal determines the Loss of Load Expectation (LOLE)
- Calculates probability of demand exceeding supply for each half hour – Loss of Load Probability (LOLP)
- Sums for whole year

# Sample LOLE calculation

Daily profile



3 Generators

Unit	Cap (MW)	FOP	Prob. of being available (1-FOP)
1	40	0.10	0.90
2	30	0.05	0.95
3	10	0.04	0.96

# Sample LOLE calculation

Unit 1 (40 MW)	Unit 2 (30 MW)	Unit 3 (10 MW)	Total Cap	Probability of each capacity	Cumulative Probability (LOLP)
0	0	0	0	$0.10 \times 0.05 \times 0.04 = 0.0002$	0.0002
0	0	1	10	$0.10 \times 0.05 \times 0.96 = 0.0048$	0.0050
0	1	0	30	$0.10 \times 0.95 \times 0.04 = 0.0038$	0.0088
0	1	1	40	$0.10 \times 0.95 \times 0.96 = 0.0912$	
1	0	0	40	$0.90 \times 0.05 \times 0.04 = 0.0018$	0.1018
1	0	1	50	$0.90 \times 0.05 \times 0.96 = 0.0432$	0.1450
1	1	0	70	$0.90 \times 0.95 \times 0.04 = 0.0342$	0.1792
1	1	1	80	$0.90 \times 0.95 \times 0.96 = 0.8208$	1.0000

- eg Prob. of Generation < 60 MW = 0.145
- LOLP summed for every half hour to give LOLE

# Sample LOLE calculation

So for each half-hour:

- $LOLP * 0.5 = LOLE$  contribution for this half-hour

- For our example day, only two load levels so

At 30 MW:  $0.0050 * 16 \text{ hours} = 0.0800$

At 60 MW:  $0.1450 * 8 \text{ hours} = 1.1600$

LOLE for day = 1.2400 hours

Repeat for every day to get annual LOLE

# AdCal – Perfect Plant

- Accepted standard is 8 hours LOLE per year
- AdCal calculates how much generation can be removed from system without breaching standard



- Surplus given in terms of Perfect Plant capacity
- Conventional generator with no outages

# AdCal Demo



# AdCal – Real Plant


- Perfect Plant must be converted back to ‘real’ plant
- Use conversion factor called Real Plant Factor (RPF)
- Create ‘ReferencePlant’ with characteristics averaged from the whole portfolio
- Insert into list of generation, observe change in surplus
- $RPF = \text{‘Reference Plant’ capacity} \div \text{change in surplus}$
- Surplus in terms of real plant can then be determined

# AdCal – Wind

- Wind profile is created using historic normalised profile
- Divide generated output by installed capacity
- Historic normalised profile is then multiplied by projected 2010 capacity to create 2010 profile
- Wind profile is deducted off load profile
- This reduced profile is the load that must be met by all other generation

# AdCal – Wind

- Capacity contribution of wind is determined by the Wind Capacity Credit Curve (WCC)
- Curve taken from previous GAR
- Remove a series of scaled up wind profiles from the load and observe change in Surplus



# Final Calculation

$$\text{Plant Capacity} + \text{Wind Capacity} - \text{Surplus} \\ = \text{Capacity requirement}$$

- Time Weighted Capacity of conventional plant is calculated
- Wind Capacity Credit is added to this to give total capacity of system
- Surplus is multiplied by RPF to give real plant Surplus
- Real plant surplus is deducted from Total Capacity of System to give Capacity Requirement

# Final Calculation

Total Capacity for Conventional:	9593
Time-Weighted Capacity for Conventional:	<b>9206</b>
Time-Weighted Capacity for Wind:	1999
Time-Weighted Capacity for Market Wind:	1514
Wind Capacity Credit	<b>269</b>
Capacity of Reference Plant	124
SOD of Reference Plant	3
FOP of Reference Plant	4.23
Surplus Generation	2450
Surplus Generation with Reference Plant	2565
Capacity Credit of Ref Plant	115
Percentage Capacity Credit of Ref Plant	92.50%
Surplus in Real Plant Terms	<b>2649</b>
<b>Capacity Requirement</b>	<b>6826</b>

# AdCal

Theory based on  
“Power System Reliability  
Evaluation”, Roy Billinton  
First Edition 1970

